

**STATE OF NEVADA
WEATHERIZATION ASSISTANCE PROGRAM**

**MINIMUM VENTILATION REQUIREMENTS
(SHELL TARGET)**

(Expressed in Cubic Feet Per Minute at 50 Pascals of House Pressure =
CFM₅₀)

NUMBER OF OCCUPANTS	NUMBER OF BEDROOMS		
	1 or Fewer	2	3 of More
1	620	930	1240
2	620	930	1240
3	930	930	1240
4	1240	1240	1240
5	1550	1550	1550
6	1860	1860	1860

Add 150 CFM₅₀ for each additional occupant beyond 6.

Note: The Minimum Ventilation Requirements (MVR) listed above are based on ASHRAE Standards and adjusted to incorporate various correction factors recommended by the Lawrence Berkeley Laboratory in an article published in the January/February 1994 issue of *Home energy*.